



## Test results

Benchmark Genetics Iceland hf.  
Bæjarhrauni 14  
220 Hafnarfjörður

Report no. : 16794-21  
Sample type: Water  
Date of reception : 22.10.2021  
Date of analysis : 22.10.2021  
Sampling: Benchmark Genetics Iceland hf.  
Contact: Hector Rodriguez  
Establishment : Seljavogur (Hafnir) - Seljavogur

Sample no.	Measurement	Result	Unit	Method
21-10794	Seljavogur, inlet, 22.10.2021			
	Total suspended solids (TSS)	<2	mg/L	Standard methods 2540 D
	BOD5	<1	mg/L	HACH-BOD direct plus, respirometric
	COD	10	mg/L	HACH - Method 8000
	Total Phosphor P	<0,1	mg/L	HACH - Method 8180
	Total Nitrogen N	<0,5	mg/L	HACH - Method 10071
	Ammonia NH <sub>3</sub> -N - wastewater	<0,4	mg/L	HACH - Method 10031
21-10796	Seljavogur, outlet, 22.10.2021			
	Total suspended solids (TSS)	<2	mg/L	Standard methods 2540 D
	BOD5	<1	mg/L	HACH-BOD direct plus, respirometric
	COD	12	mg/L	HACH - Method 8000
	Total Phosphor P	0,1	mg/L	HACH - Method 8180
	Total Nitrogen N	0,9	mg/L	HACH - Method 10071
	Ammonia NH <sub>3</sub> -N - wastewater	<0,4	mg/L	HACH - Method 10031

Kópavogur, 28.10.2021

This is electronically generated laboratory report  
and has been checked and approved.  
It is valid without signature.

Magnús Snær Árnason  
Food Scientist